



The Public Health and Safety Organization

## NSF/ANSI/CAN 61

### Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. [Click here for a list of Abbreviations used in these Listings.](#) [Click here for the definitions of Water Contact Temperatures denoted in these Listings.](#)

#### Bright Sheland International Co., Ltd.

No.5, Ko Kung 1st Road

Douliou, Yunlin Hsien 640

Taiwan

886 5 5512322

Facility : Kunshan, Jiangsu, China

#### Mechanical Devices

Trade Designation	Size	Water Contact Temp	Water Contact Material
<b>Filtration Devices/Components[1] [2] [G]</b>			
Poly-ADCT (PATX-XXP)	[3] [4] [5] [6]	CLD 23	PP
Puris-Fine (PRSX-XX)	[3] [4] [5] [6]	CLD 23	PP
Superior-Fine (PCBX-XX)	[3] [4] [5] [6]	CLD 23	PP

[1] Certification does not include any end connection, gasket, or o-ring options. Product has not been evaluated for point-of-end (POE) or point-or-use (POU) end uses.

[2] Certified for a minimum daily flow of 1,870 L per 3" of cartridge length.

[3] X - Retention Rating: 0.5 µm - 200 µm

[4] XX - Cartridge Length: 3" - 100"

[5] Inner Diameter: 28 mm

[6] Outer Diameter: 60 mm - 115 mm

[G] Product is Certified to NSF/ANSI 372 and conforms with the lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Number of matching Manufacturers is 1

Number of matching Products is 3

Processing time was 0 seconds